

# NEW TOWN KOLKATA DEVELOPMENT AUTHORITY

(A Statutory Authority Under Government of West Bengal)  
3, Major Arterial Road, New Town, Kolkata - 700 156

## ADVISORY

In connection with the "First Aid Firefighting and rescue equipment to be maintained/ kept in Fire Service Kiosk within High Rise/ High Risk occupancies" it is to be ensured that, one dedicated Kiosk measuring 200 sq.mt. area, preferably located at ground floor for the following type of buildings:

1. All stand-alone Residential Buildings above 45 Mtr. Height.
2. All Residential Complex having floor area more than 2.0 Lac. Sq.ft.
3. All educational occupancy having provision of air conditioning, basement parking, laboratory, auditorium of 500 person capacity and market complexes.
4. Other High Risk Buildings as specified in this Department's Notification No. 279/DS/FS/O/C-1/FIA-3/96, dated 08.07.2003 depending upon Building's vulnerability to Fire.

Such kiosks shall contain the following equipment:

- i. 4 nos. 4.5 kg. CO2 extinguisher.
- ii. 4 nos. 4.5 kg. ABC type extinguisher.
- iii. 2 nos. ceiling hook.
- iv. 4 nos. Fire Bucket.
- v. 1 no. Lock Cutter.
- vi. 2 nos. 14 lb. Hammer.
- vii. 2 nos. Crowbar.
- viii. 1 no. Insulated Axe.
- ix. 2 nos. Stretcher.
- x. 2 nos. Smoke Hood.
- xi. 2 nos. Torch Light.

  
Chief Executive Officer  
New Town Kolkata Development Authority

Memo No. 3654 /NKDA/Admn(BPS) – 415/11/2009

Date: 26.07.2019

Copy forwarded for information to:

1. Joint Managing Director, WBHIDCO
2. Executive Director, WBHIDCO
3. Chief Engineer, WBHIDCO

4. Chief Engineer, NKDA
5. Chief Architect, NKDA
6. Executive Architect, NKDA
7. All GMs, WBHIDCO
8. All Executive Engineer, NKDA



**Chief Executive Officer**  
**New Town Kolkata Development Authority**